

Ordered by:

Kontaktsysteme AG
Lerzenstr. 8
CH-8953 Dietikon

Test Laboratory:

häusler netzwerk-beratung gmbh
Guggenbühlstrasse 13
8953 Dietikon
Phone: +41-44-740 60 07
E-Mail: walter.haeusler@whnb.ch
Fax: +41-44-740 60 01
Mobile: +41-79-33 55 44 9

Test Report-Nr.:

10.11.2006

Test Description:

Systemtest: Permanent Link and Channel

Installation Cable (IC):

Dätwyler UNINET 7002
4P AWG23 FRNC/LSOH
Artikel No.: 177 388
Länge: 15, 45, 90m

Patchcord:

LANmark / ISCS-6 10G ULTIM
Länge: 2, 5, 10m

Modul (TA):

Nexans LANmark-6, 10G Evo
Artikel No.: N420.666G

Test Standards:

ISO/IEC 11801:2002 Permanent Link, Class E
ISO/IEC 11801:2002 Channel, Class E
ISO/IEC 11802:2002 Patchcord, Cat.6

Test Results:

- **All Links fulfill the requirements in accordance**
with the demanded test standards:
- ISO/IEC 11801 Permanent Link, Class E
- ISO/IEC 11801 Channel, Class E

Dietikon, November 10, 2006



Walter Häusler
Test Manager, hnb



Markus Huber
CEO, Kontaktsysteme AG



Heinz Giger
KIPD 21, Credit-Suisse